

## REPORT OF CHEMICAL ANALYSIS

REPORT NUMBER 2800603

Rain Again PL

PO Box 1076

Newport Beach

NSW 2106

Lab. Ref. No.	DOH No.	Township	Sampling Point	Sampling Date	Date Received
2801599	Drinking water	Rain Again		26/05/2008	26/05/2008

	2801599
Aluminium	<0.01
Antimony	<0.001
Arsenic	<0.001
Barium	<0.1
Boron	<0.1
Cadmium	<0.001
Calcium	<0.1
Chloride	1
Chromium	<0.01
Copper	<0.1
Fluoride	<0.10
Fluoride (Client Result)	0.00
Fluoride Ratio	0.00
Iodine	<0.020
Iron	<0.1
Lead	<0.01
Magnesium	<0.1
Manganese	<0.01
Mercury	0.0001
Molybdenum	<0.01
Nickel	<0.01
Nitrate	<1.0
Nitrite	<0.1
pH	6.6
Selenium	<0.01
Silver	<0.01
Sodium	1
Sulfate	<1
TDS	<5
Total Hardness as CaCO <sub>3</sub>	<1
True Colour	<1
Turbidity	0.1
Zinc	<0.1

## Comments :

Approved Signatories: Metals: S Frederickson, Nutrients: L Aparra, All inorganics: S Gantert-metals, H Louie

Please Note : The results of analysis contained in this report refer only to the sample(s) tested.

Trace metals results refer to unfiltered samples tested as received.

Values with \*\*\* exceed Australian Drinking Water Guidelines

Results in mg/L except for Turbidity (NTU), Colour (HU), Conductivity ( $\mu$  S/cm) and pH

Date : Monday, 2 June, 2008

Page No. : Page 1 of 1



Honway Louie

(Contact person, Sr. Scientist)

FAXED 2 JUN 2008